



DCS Workshop
March 1, 2002



Status of HCAL Controls

J. Rohlf


Boston University

HCAL FE/DAQ Overview

Out of HTR
by 8's

Slink (DAQ: 64 bits @ 25 MHz)

(Trigger: 32 bits @ 2 MHz)



HCAL Electronics

front end

HB 36 RBX (HPD+QIE)
HE 36 RBX
HO 36 RBX
HF 24 3u crates (QIE) + 72 PMT boxes




digital

	channels	fibers	trig towers	SLB	HTR	crates	HTR/crate
HB (pure)	1728	576	1728	216	36	3	12
HB/HE overlap	1728	576	864	108	36	3	12
HE (pure)	1728	576	1440	180	36	3	12
HO	2160	720			48	4	12
HF	1800	600	144	18	38	3	12.67

TOTAL 9144 3048 4176 522 194 16

20° slice: 144 ch. (3 HTR)



HCAL DAQ Partitions

partition 1
12 HTR/crate

HB/HE	HB/HE
+	-
40°	40°

HB/HE	HB/HE
+	-
40°	40°

HB/HE	HB/HE
+	-
40°	40°

partition 2
12 HTR/crate

HB/HE	HB/HE
+	-
40°	40°

HB/HE	HB/HE
+	-
40°	40°

HB/HE	HB/HE
+	-
40°	40°

partition 3
12 HTR/crate

HB/HE	HB/HE
+	-
40°	40°

HB/HE	HB/HE
+	-
40°	40°

HB/HE	HB/HE
+	-
40°	40°

partition 4
12 HTR/crate

HO	HO
+	-
45°	45°

HO	HO
+	-
45°	45°

HO	HO
+	-
45°	45°

HO	HO
+	-
45°	45°

partition 5
12/13 HTR/crate

HF	HF
+	-
120°	120°

HF	HF
+	-
120°	120°

HF	HF
+	-
120°	120°

HCAL DCS Components:

High Voltage (HPD, PMT)

Low Voltage (FE)

FPGA Configuration (FE, HTR, DCC)

Laser (pulse once per month)


LED (diagnostic only)

Source Calibration (once per year)


Event Spy (continuous)

HCAL DCS Overview


- HV power supply monitoring
- LV power supplies monitoring
- LV + T on-board monitoring
- Source calibration
- Laser calibration
- LED calibration
- FPGA configuration



Logical and Physical Trees




HV system structure (I)




HV system structure (II)

HV control system software architecture




Low Voltage Control System




CMS HCAL TIMING & CONTROL MODULE(CCM)

- MONITOR BOARD FUNCTION
 - Monitor supply voltages
 - 3 voltages regulated
 - Monitor temperature of RBX boards
 - 6 Front End boards
 - 1 CCM module
 - Monitor Board – Parts
 - Analog Devices Parts
 - AD670 8–Bit Analog to Digital Convertor
 - ADG670 16–Channel Multiplexer
 - AD590 Temperature Sensor


CMS HCAL CLOCK & CONTROL MODULE(CCM)




Laser Calibration




LED Calibration



Moving Table (Test Beam Only)



Source Calibration Control



Basic Source Calibration Parameters


HCAL Stand-alone DAQ


5 mC source


Moving at 10 cm/s

Data every 2 mm (20 ms)

Need ~1M events for 2% calibration







Boston University EDF
P/N DCC-demo 4/2001 S. X. Wu

TTCrx

PCI-1
32 bit
33 MHz


PCI-3
64 bit
33 MHz


Xilinx
XC2V1000

DDR
SDRAM

Slink

PCI-2
32 bit
33 MHz





Run 10261, pedestal Ch. B all Caps

0.4 M events

18.089 ± 0.002

$\sigma = 1.603 \pm 0.002$


(3300 electrons)

EXT PARAMETER

STEP FIRST

NO.	NAME	VALUE	ERROR	SIZE	DERIVATIVE
1	Constant	0.11041E+06	200.12	279.31	-0.41532E-07
2	Mean	18.589	0.24187E-02	0.47027E-01	-16.952
3	Sigma	1.6027	0.16153E-02	0.40546E-02	-13.280

CHISQUARE = 0.5797E+02 NPFIT = 18



**Run 10261, pedestal
Ch. B Cap ID = 0**

0.1 M events


18.550 ± 0.004

$\sigma = 1.324 \pm 0.003$

(2750 electrons)

EXT	PARAMETER	STEP	FIRST		
NO.	NAME	VALUE	ERROR	SIZE	DERIVATIVE
1	Constant	33454.	124.09	84.632	-0.91608E-05
2	Mean	19.050	0.39749E-02	0.48194E-01	0.17653
3	Sigma	1.3239	0.28546E-02	0.33492E-02	-2.5962

CHISQUARE = 0.7285E+01 NPFIT = 15



**Run 10261, pedestal
Ch. B Cap ID = 1**


0.1 M events

17.812 ± 0.004

$\sigma = 1.323 \pm 0.003$

(2750 electrons)

EXT	PARAMETER			STEP	FIRST
NO.	NAME	VALUE	ERROR	SIZE	DERIVATIVE
1	Constant	33456.	124.61	84.639	-0.63124E-05
2	Mean	18.312	0.39740E-02	0.46326E-01	1.7546
3	Sigma	1.3234	0.28851E-02	0.33480E-02	-2.7766
CHISQUARE = 0.9096E+01		NPFIT = 16			



**Run 10261, pedestal
Ch. B Cap ID = 2**

0.1 M events


19.220 ± 0.004

$\sigma = 1.319 \pm 003$

(2740 electrons)

EXT	PARAMETER	STEP	FIRST		
NO.	NAME	VALUE	ERROR	SIZE	DERIVATIVE
1	Constant	33573.	124.74	84.934	-0.60208E-05
2	Mean	19.720	0.39635E-02	0.49887E-01	-0.59073
3	Sigma	1.3190	0.28620E-02	0.33369E-02	-2.9135

CHISQUARE = 0.8460E+01 NPFIT = 15



**Run 10261, pedestal
Ch. B Cap ID = 3**

0.1 M events


16.782 ± 004

**$\sigma = 1.337 \pm 0.003$
(2780 electrons)**

EXT	PARAMETER	STEP	FIRST		
NO.	NAME	VALUE	ERROR	SIZE	DERIVATIVE
1	Constant	33111.	123.52	83.766	-0.12907E-04
2	Mean	17.282	0.40153E-02	0.43721E-01	-0.96354
3	Sigma	1.3372	0.29311E-02	0.33828E-02	-2.4250
CHISQUARE = 0.9296E+01		NPFIT = 16			

Data of 31-Jan-02, Ch. B (all Caps)

**Mean
(channels)**




**HPD: 7000 kV, 90 V bias,
QIE: calibration mode**

**supp.
zero**


time (minutes) Time (min)

Run 10269, Ch. B, all Caps

Mean
(channels)




Run 10269, Ch. B, all Caps




Run 10287, Ch. B, all Caps


Number of
measurements
(0.5 M events)
per 0.002 ch.



Run 10275, Cap ID = 3

**Dist. of
widths
(meas. per
0.002 ch.)**





1 M events


**From mean:
0.0870 ± 0.0017**

**From fit (g+p):
0.0876 ± 0.0015
(182 ± 3 elec.)**

EXT	PARAMETER	STEP	FIRST		
NO.	NAME	VALUE	ERROR	SIZE	DERIVATIVE
1	P1	0.24146E+06	242.91	610.84	-0.88025E-04
2	P2	0.87629E-01	0.14759E-02	0.31000E-02	24.093

CHISQUARE = 0.1585E+03 NPFIT = 24

Run 10287, Ch. B, all Caps



From fit (4g+p):
 0.0867 ± 0.0015


Comments:

- 1) This is a check of the observed pulse shape with source
- 2) Need to know mean from each cap to do this fit

EXT	PARAMETER	STEP	FIRST		
NO.	NAME	VALUE	ERROR	SIZE	DERIVATIVE
1	P1	98728.	99.169	-7.3996	0.53694E-05
2	P2	0.86691E-01	0.14941E-02	-0.31544E-04	1.8051

CHISQUARE = 0.5055E+02 NPFIT = 24

Run 10301, Ch. B, Cap ID = all




**Stability of source signal good
to better than 1%
as observed over one month**

Feb. 25, 2002

Source
Signal

(LC above ped.)

suppressed
zero



CERN CMS Week March 2001: Source test as spin-off of demonstrator was born

SOURCE 10 cm/SEC

data point every 2 mm

$\Delta t = 20 \text{ nsec}$, use 10 nsec ; 4×10^5 bkts

DATA POINT, $\approx 10^7$ readings

? how fast


$$10^7 \times 25 \times 10^{-9} = \frac{1}{4} \text{ sec}$$

3

$$\Lambda_{Cu} = 3.7 \cdot 10^9 \frac{\text{decays}}{\text{sec}}$$

$\sim 4 \cdot 10^9$

$$1 \mu\text{m Cu} = 4 \cdot 10^6 \text{ decays/sec}$$



HISTO MODE

128 M bytes/sec S-Link, Channel Link
(1 byte/readings)
gen 40 M readings/sec

→ Streaming mode
format, 1chan → 1 byte
+ loss exponent

$$10 \times 32 = 320 = 8/\text{dec}$$



Conclusions (source calibration):

Calibration of HCAL by radioactive source to $\leq 2\%$ can be made to work, (the "source test" is completed)

Scintillator + fibers, HPD, QIE, TTCvx, TTCvi, Glink, HTR, LVDS link, DCC, Slink, VME CPU have been successfully integrated!

(2 channels, $\times 5000$ to do)

Detector Controls Work List

- 1) **Finish HV (2 crate test + documentation)**
- 2) **Test beam environment**
- 3) **LV (custom code and SCADA panels)
hardware and software**
- 4) **Source (wrapper on CDF with DIM)
this system will then evolve to meet our
specific needs and DCS framework**
- 5) **Laser**
- 6) **Event spy and FPGA code loading**

HCAL DCS Plans:

Test Beam 2002 (24 July–10 Sept.)

**Computer control of
HV, CCM, Source, Moving Table**

Bandwidth for Testbeam

Spill is 5.2 s on, 11.6 s off


Trigger rate = 5 kHz

$(144 \text{ ch.})(10 \text{ Bytes/ch.})(5000/\text{s})(5 \text{ s}) = 1.5 \text{ MB/s}$

8 MBytes per spill

30 MBytes/m or 2 GByte per hour



CERN 2002 Test Beam



VME Interface:


High I/O rackmount PC driving
an SBS/Bit3 VME master board
via PCI interface

Optical Fiber
Link




VME Read Results

Read Test




VME Write Results

Write Test



Software Architecture: HCAL Local DAQ



Requests

1. For JCOP

- Extension of the HV framework to HCAL HV Power supplies
- Stability of releases (do not change philosophy)
- Description and toolkit for all interfaces including interface of PVSS DB to external (condition) DB.
- humidity control
- gas control (primitive)
- cooling control

2. For CMS DCS group

- Continuation of development and definition of
 - Interfaces
 - Naming scheme (naming convention)